















Wyniki - Nastawy

Typ	Symbol	Dn	Nastawa	Q	Kv	dP	Qcyr	Kvcyr	dPcyr
		[mm]		[l/s]	[m <sup>3</sup> /h]	[m]	[l/s]	[m <sup>3</sup> /h]	[m]
	MTCV-B	15	50°C Xp=5				0,008	0,366	0,056
	MTCV-B	15	48°C Xp=3,25				0,001	0,254	0,004
	MTCV-B	15	45°C Xp=3,00				0,001	0,241	0,005
	MTCV-B	15	46°C Xp=4,00				0,002	0,297	0,009
	MTCV-B	15	43°C Xp=0.5				0,004	0,152	0,090
	MTCV-B	15	48°C Xp=3,50				0,002	0,268	0,004
	MTCV-B	15	49°C Xp=4,00				0,002	0,297	0,006
	TA-MATIC	20	43°C	0,36	2,500	2,69			
	TA-MATIC	20	43°C	0,28	2,500	1,63			
	AQUASTR C 71	15	1,65				0,002	0,082	0,073
	AQUASTR C 71	15	1,69				0,002	0,085	0,111
	AQUASTR C 71	15	1,27				0,001	0,056	0,090
	AQUASTR C 71	15	1,31				0,001	0,058	0,067
	AQUASTR C 71	15	1,38				0,002	0,063	0,075